



Advisory 2021-02

Security update for CODESYS V3 Package Manager

Published: 28 April 2021

Version: 2.0

Template: templ_tecdoc_en_V3.0.docx

File name: Advisory2021-02_CDS-40084.docx

CONTENT

	Page	
1	Affected Products	3
2	Vulnerability overview	3
2.1	Type	3
2.2	Management Summary	3
2.3	References	3
2.4	Severity Rating	3
3	Vulnerability details	3
3.1	Detailed Description	3
3.2	Exploitability	3
3.3	Difficulty	3
3.4	Existence of exploit	3
4	Available software updates	3
5	Mitigation	4
6	Acknowledgments	4
7	Further Information	4
8	Disclaimer	4
	Bibliography	5
	Change History	5

1 Affected Products

All CODESYS Development System V3 versions prior V3.5.17.0 are affected by this vulnerability. This applies to both the 32-bit and 64-bit variants.

2 Vulnerability overview

2.1 Type

CWE-345: Insufficient Verification of Data Authenticity [7]

2.2 Management Summary

The Package Manager of the CODESYS Development System does not check the validity of packages before installation and may be used to install CODESYS packages with malicious content.

2.3 References

CVE: CVE-2021-29240 [6]

CODESYS JIRA: CDS-40084

2.4 Severity Rating

CODESYS GmbH has rated this vulnerability as high.

The CVSS v3.0 base score of 7.8 has been assigned. The CVSS vector string is (CVSS:3.0/AV:L/AC:L/PR:N/UI:R/S:U/C:H/I:H/A:H). [8]

3 Vulnerability details

3.1 Detailed Description

The CODESYS Development System is an IEC 61131-3 programming tool for the industrial controller and automation technology sector. Optional CODESYS features or plugins were provided as CODESYS packages. The Package Manager of the CODESYS Development System does not check the validity of packages before installation. Thus, a user may install CODESYS packages with malicious content without getting any warning.

3.2 Exploitability

This vulnerability could be exploited by or with the help of local users.

3.3 Difficulty

An attacker with low skills would be able to exploit this vulnerability.

3.4 Existence of exploit

No known public exploits specifically target this vulnerability.

4 Available software updates

CODESYS GmbH has released version V3.5.17.0 to solve the noted vulnerability issue for all affected products. Please visit the CODESYS update area for more information on how to obtain the software update [3].

After applying the software update, the Package Manager of the CODESYS Development System checks, if the package to install was correctly signed based on a valid certificate. Therefore, we signed now all previously released CODESYS packages to get them trustworthy. Since the signature is part of the packets, the file size and also file checksums or hashes of these packages have changed with otherwise the same packet content.

CODESYS GmbH also encourages all package vendors to sign their packages so that they are displayed and treated as trusted.

5 Mitigation

CODESYS GmbH recommends using the available software update to fix the vulnerability.

CODESYS GmbH has currently found no workaround for this vulnerability. Therefore, you should only install and use CODESYS packages from trustworthy sources, in case the software update is not applied.

As part of a security strategy, CODESYS GmbH recommends the following general defense measures to reduce the risk of exploits:

- Use controllers and devices only in a protected environment to minimize network exposure and ensure that they are not accessible from outside
- Use firewalls to protect and separate the control system network from other networks
- Use VPN (Virtual Private Networks) tunnels if remote access is required
- Activate and apply user management and password features
- Use encrypted communication links
- Limit the access to both development and control system by physical means, operating system features, etc.
- Protect both development and control system by using up to date virus detecting solutions

For more information and general recommendations for protecting machines and plants, see also the CODESYS Security Whitepaper [1].

6 Acknowledgments

CODESYS GmbH thanks those in the security community, who help us to improve our products and to protect customers and users through coordinated vulnerability disclosure.

This issue was discovered by Uri Katz of Claroty. We thank for reporting it following coordinated disclosure.

7 Further Information

For additional information regarding the CODESYS products, especially the above-mentioned versions, or about the described vulnerability please contact the CODESYS support team [5].

8 Disclaimer

CODESYS GmbH assumes no liability whatsoever for indirect, collateral, accidental or consequential losses that occur by the distribution and/or use of this document or any losses in connection with the distribution and/or use of this document. All information published in this document is provided on good faith by CODESYS GmbH. Insofar as permissible by law, however, none of this information shall establish any guarantee, commitment or liability on the part of CODESYS GmbH.

Note: Not all CODESYS features are available in all territories. For more information on geographic restrictions, please contact sales@codesys.com.

Bibliography

- [1] CODESYS GmbH: [CODESYS Security Whitepaper](#)
- [2] CODESYS GmbH: [Coordinated Disclosure Policy](#)
- [3] CODESYS GmbH update area: <https://www.codesys.com/download>
- [4] CODESYS GmbH security information page: <https://www.codesys.com/security>
- [5] CODESYS GmbH support contact site: <https://www.codesys.com/support>
- [6] Common Vulnerabilities and Exposures (CVE): <https://cve.mitre.org>
- [7] Common Weakness Enumeration (CWE): <https://cwe.mitre.org>
- [8] CVSS Calculator: <https://www.first.org/cvss/calculator/3.0>
- [9] ICS-CERT: <https://ics-cert.us-cert.gov>

The latest version of this document can be found here:

<https://customers.codesys.com/index.php?eID=dumpFile&t=f&f=14636&token=1ce7e6e4cbe4651989ede418450d7c82e972bdf2&download=>

Change History

Version	Description	Date
1.0	First version	29.03.2021
2.0	Software update available	28.04.2021